



and Certification Laboratories

廠商會檢定中心

TEST REPORT

Report No. : AT0 62()

Date : 27 Jul 2015

Application No. : LT031 ()

Test Result : 世衛安全標準為 10 微克/L

Sample ID	Lead ($\mu\text{g/L}$)
WHO 2011 Guideline Value ^(Note 5)	10
1	32
2	<2

住宅原水含鉛 32 微克/L

Note:

1. < denotes less than
2. $\mu\text{g/L}$ denotes microgram per litre
3. APHA denotes American Public Health Association, Standard Method for the Examination of Water & Wastewater 21ed, 2005.
4. Result may be deviated if sampling, delivery and sample storage conditions are not complied with APHA 21ed 1060C.
5. World Health Organization's (WHO) Guidelines for Drinking-water Quality (2011).

C1000-UF 過濾後低於 2 微克/L

***** End of Report *****

IMPORTANT

This REPORT is for our customer and other persons concerned ONLY.