

## Test Report

No. HKEET1508002175ES

Date : Sep 01, 2015 Page 1 of 1

BRIMED HEALTH TECHNOLOGY LTD.  
G/F, 205A, WAI YIP STREET, KWUN TONG, HONG KONG

SGS CASE No. : HKES150800001842

Report on sampling and laboratory testing of the collected samples from 啟晴邨 identified as Drinking Water.

### 1. Sample Identification

Sample No. Assigned by SGS	Sampling Location	Date & Time of Commencing Sampling
W15081619	A - 住宅原水 (不放水)	Aug 25, 2015 0900
W15081620	B - C1000 - UF (放水)	Aug 25, 2015 0905
W15081621	C - C2000 - UF (放水)	Aug 25, 2015 0910
W15081622	D - Shower Filter (不放水)	Aug 25, 2015 0915
W15081623	E - 大堂原水 (不放水)	Aug 25, 2015 0920

Sampling : Conducted by SGS  
Quantity of Each Sample and : 1 x 250ml in a plastic bottle with 2ml 6N HNO<sub>3</sub> added to pH < 2  
Preservation Employed :  
Sample Delivery : By SGS on Aug 25, 2015 under refrigerated condition  
Sample Receiving Date : Aug 25, 2015  
Testing Period : Aug 25, 2015 - Aug 31, 2015

### 2. Test Method and Testing Results

A - 住宅原水 19ug/L  
，超標 1 倍。

B&C - 過濾後鉛低於  
1ug/L達檢測度下限。

Parameter	Reference Method	W15081619	W15081620	W15081621	Guidelines for Drinking Water Quality, WHO, 4 <sup>th</sup> edition, 2011
Lead (mg/L)	In House Method (ICP-MS)	0.019	< 0.001	< 0.001	0.01

Parameter	Reference Method	W15081622	W15081623	Guidelines for Drinking Water Quality, WHO, 4 <sup>th</sup> edition, 2011
Lead (mg/L)	In House Method (ICP-MS)	0.0081	0.019	0.01

D - Shower Filter 過濾後含鉛約 8ug/L，符合世衛安全標準。

E - 為暫緩鉛水而增設的大堂臨時供水喉，也檢出 19ug/L，同樣超標。

Signed for and on behalf of  
SGS Hong Kong Ltd.

Freda Lai  
Section Manager

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at [www.sgs.com/terms\\_and\\_conditions.htm](http://www.sgs.com/terms_and_conditions.htm) and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at [www.sgs.com/terms\\_e-document.htm](http://www.sgs.com/terms_e-document.htm). Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

